



OFFICE OF THE SUPERINTENDENT
SOUTH HADLEY FIRE DISTRICT NO. 2, WATER DEPARTMENT
20 Woodbridge Street * South Hadley MA 01075
Telephone: 413-532-9210 * Fax: 413-534-5949
www.shdistrict2.org

136 East Street sub-division

The water for the proposed sub-division at 136 East Street will be supplied by an existing 8" water main that is located on the opposite side of the road from the project. A new 8" water main will be connected to the existing main and the contractor will run the main according to the plans submitted. The static pressure in that area is approximately 55 lbs. with a flow rate from the nearby hydrant being at least 1200 gallons per minute. There is plenty of water and flow in the existing main to support the proposed sub-division.

Sincerely,

Tim Cauley

Superintendent